

Indicating Valves, Butterfly or Ball Type

Design features provide a dependable visible indication of the open position even at a distance. If excessive force is applied to the handle, weakness-joints will break so as to preserve correct orientation between indicator and valve position. Valve and indicator parts are so designed that they can be assembled only one way, always to give correct indication. All FM Approved indicating valves turn clockwise to shut. They are small, lightweight, and, because of a resilient seat, are easy to operate. They are not subject to sticking or dropped gates. They are not recommended for throttling service. Unless otherwise noted in the listing, these valves have 175 psi (1205 kPa) rated working pressure.

Models SFL-BV-300-W, SFL-BV-300-WX, SFL-BV-300-G, SFL-BV-300-GX

| Model Number | Product Type | Nominal Pipe Size, in. (mm) | Rated Working Pressure, psi (kPa) | Remarks |
|---------------------|--------------------------------------------------|------------------------------------------------------|------------------------------------------|----------------|
| SFL-BV-300-W | Butterfly Valve, Wafer by Wafer End Connections | 2-1/2, 3, 4, 5, 6, 8 (65, 80, 100, 125, 150, 200) | 300 (2070) | a, b, c |
| SFL-BV-300-WX | Butterfly Valve, Wafer by Wafer End Connections | 10, 12 (250, 300) | 300 (2070) | a, b, c |
| SFL-BV-300-G | Butterfly Valve, Groove x Groove End Connections | 2-1/2, 3, 4, 5, 6, 8 (65, 80, 100, 125, 150, 200) | 300 (2070) | a, b, c |
| SFL-BV-300-GX | Butterfly Valve, Groove x Groove End Connections | 10, 12 (250, 300) | 300 (2070) | a, b, c |

Remarks:

- a. Available with or without supervisory switches.
- b. FM Approved for indoor and outdoor service.
- c. FM Approved for aboveground installations only.

| | |
|-------------------------------------|-----------------------------------------------------------|
| Company Name: | Sanflo Technologies |
| Company Address: | 401 E. 1st Street #1868-0268, Sanford, Florida 32772, USA |
| Company Website: | Not Available |
| New/Updated Product Listing: | No |
| Listing Country: | United States of America |
| Certification Type: | FM Approved |
| Class of Work: | 1112-Indicating Valves |