



HMRZ.EX27743 - GATE VALVES

Gate Valves

See General Information for Gate Valves

SANFLO TECHNOLOGIES

401E 1ST STREET #1868-0268

SANFORD, FL 32772 USA

EX27743

Pattern	Model	Size, in.	End Configuration	Rated Pressure, psig
OS&Y	SFL-OSY-300-F	2.5,3,4,5,6,8,10,12	Flange & Flange	300
NRS	SFL-NRS-300-F	2.5,3,4,5,6,8,10,12	Flange & Flange	300
OS&Y	SFL-OSY-200-F	2,2.5,3,4,5,6,8,10,12	Flange & Flange	200
	SFL-OSY-200-FG		Flange & Grooved	
	SFL-OSY-200-G		Grooved & Grooved	
NRS	SFL-NRS-200-F	2.5,3,4,5,6,8,10,12	Flange & Flange	200
	SFL-NRS-200-FG		Flange & Grooved	
	SFL-NRS-200-G		Grooved & Grooved	

Note:O.S&Y, outside-screw-and-yoke type NRS, nonrising stem type.

Flanges comply with ANSI B16.1 Class 125; for 300 psi, use Face flange, for 200 psi, use Raised-face flange.

Last Updated on 2018-01-29

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2019 UL LLC"