

UL Product iQ™



HMRZ7.EX27743 - GATE VALVES CERTIFIED FOR CANADA

Gate Valves Certified for Canada

See General Information for Gate Valves Certified for Canada

SANFLO TECHNOLOGIES

EX27743

401E 1ST STREET #1868-0268

SANFORD, FL 32772 USA

O. S. and Y. pattern, Model SFL-OSY-300-F, F by F end configuration, in 2.5, 3, 4, 5, 6, 8, 10 or 12 in. sizes for working pressure of 2068 kPa.

NRS. pattern, Model SFL-NRS-300-F, F by F end configuration, in 2.5, 3, 4, 5, 6, 8, 10 or 12 in. sizes for working pressure of 2068 kPa.

O. S. and Y. pattern, Model SFL-OSY-200-F, F by F end configuration in 2, 2.5, 3, 4, 5, 6, 8, 10 or 12 in. sizes for working pressure of 1379 kPa.

O. S. and Y. pattern, Model SFL-OSY-200-FG, F by G end configuration in 2, 2.5, 3, 4, 5, 6, 8, 10 or 12 in. sizes for working pressure of 1379 kPa.

O. S. and Y. pattern, Model SFL-OSY-200-G, G by G end configuration in 2, 2.5, 3, 4, 5, 6, 8, 10 or 12 in. sizes for working pressure of 1379 kPa.

NRS. pattern, Model SFL-NRS-200-F, F by F end configuration, in 2.5, 3, 4, 5, 6, 8, 10 or 12 in. sizes for working pressure of 1379 kPa.

NRS. pattern, Model SFL-NRS-200-FG, F by G end configuration, in 2.5, 3, 4, 5, 6, 8, 10 or 12 in. sizes for working pressure of 1379 kPa.

NRS. pattern, Model SFL-NRS-200-G, G by G end configuration, in 2.5, 3, 4, 5, 6, 8, 10 or 12 in. sizes for working pressure of 1379 kPa.

Note: O.S&Y, outside-screw-and-yoke type NRS, nonrising stem type.

Flanges comply with ANSI B16.1 Class 125; for 2068 KPa, use Face flange, for 1379 KPa, use Raised-face flange.

Last Updated on 2018-01-29

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2019 UL LLC"