

Model SFL-ACV-G

File Number: EX28674

COMPANY

SANFLO TECHNOLOGIES

411 West 1st Street #1005

Sanford, FL 32771 United States

MODEL INFO

SFL-ACV-G

Alarm Valve

PRODUCT INFORMATION

Body Type	Nom Pipe Size, NPS	End Configuration	Max Rated Pressure, psig (kPa)	Supply Pressure Type	Alarm Device Type	Alarm Device Model	Retard Chamber Model	Installed Position
Globe	2, 2-1/2, 65 mm, 3, 76.1 mm, 4, 5, 139.7 mm, 6, 165.1 mm, 8, 219.1 mm, 10, 12	Groove	300 (2068)	Variable	Water motor gong	SFL-WMAG	SFL-RET	Vertical
Globe	2, 2-1/2, 65 mm, 3, 76.1 mm, 4, 5, 139.7 mm, 6, 165.1 mm, 8, 219.1 mm, 10, 12	Groove	300 (2068)	Variable	Electric pressure switch	UL Listed (VOXZ)	SFL-RET	Vertical
Globe	2, 2-1/2, 65 mm, 3, 76.1 mm, 4, 5, 139.7 mm, 6, 165.1 mm, 8, 219.1 mm, 10, 12	Groove	300 (2068)	Constant	Water motor gong	SFL-WMAG	Not Applicable	Vertical
Globe	2, 2-1/2, 65 mm, 3, 76.1 mm, 4, 5, 139.7 mm, 6, 165.1 mm, 8, 219.1 mm, 10, 12	Groove	300 (2068)	Constant	Electric pressure switch	UL Listed (VOXZ)	Not Applicable	Vertical

GENERAL

Installation Limitations

End configurations are intended to be installed on systems not exceeding end configurations' working capabilities.

Report Date: 2025-07-30

UL Solutions permits the reproduction of the material contained in Product iQ subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from Product iQ with permission from UL Solutions" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "©2026 UL LLC."