

Sprinkler System Components | Water Motor Gongs | Waterflow Alarm System Valves

Models SFL-ACV-G, SFL-ACV-F, SFL-ACV-FGA and SFL-ACV-FGB

Product Description

Model No	Description	Valve Size		Rated Working Pressure		End Connection	Remarks
		in	(mm)	psi	(kPa)		
SFL-ACV-G	Alarm Check Valve	2, 2 1/2, 3, 4, 5, 6, 8, 10, 12	(50, 65, 80, 100, 125, 150, 200, 250, 300)	300	(2065)	Grooved x Grooved	a, b, c
SFL-ACV-F	Alarm Check Valve	2, 2 1/2, 3, 4, 5, 6, 8, 10, 12	(50, 65, 80, 100, 125, 150, 200, 250, 300)	300	(2065)	Flanged x Flanged	a, b, c
SFL-ACV-FGA	Alarm Check Valve	2, 2 1/2, 3, 4, 5, 6, 8, 10, 12	(50, 65, 80, 100, 125, 150, 200, 250, 300)	300	(2065)	Flanged x Grooved	a, b, c
SFL-ACV-FGB	Alarm Check Valve	2, 2 1/2, 3, 4, 5, 6, 8, 10, 12	(50, 65, 80, 100, 125, 150, 200, 250, 300)	300	(2065)	Grooved x Flanged	a, b, c

Remarks:

- a. Resilient seat.
- b. FM Approved for Vertical Installations Only
- c. Approved for use with Model SFL-RET retard chamber

Details

Category	Waterflow Alarm System Valves
Class of Work	1041 - Alarm Check Valves
Approval Standard	FM 1041 - Alarm Check Valves
Certification Type	FM Approved
Listing Country	United States of America

Company

Sanflo Technologies
411 W. 1st Street, #1005, Sanford
, Florida 32771
United States of America
<http://sanflotek.com>